

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE <b>J</b>		PAGE OF PAGES <b>1   7</b>	
2. AMENDMENT/MODIFICATION NO. <b>0005</b>		3. EFFECTIVE DATE <b>23-Aug-2002</b>		4. REQUISITION/PURCHASE REQ. NO. <b>W16ROE-2156-1458</b>		5. PROJECT NO.(If applicable)	
6. ISSUED BY USA ENGINEER DISTRICT, NEW YORK ATTN: CENAN-CT ROOM 1843 26 FEDERAL PLAZA (DACA51) NEW YORK NY 10278-0090		CODE <b>DACA51</b>		7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. <b>DACA51-02-R-0017</b>	
				X		9B. DATED (SEE ITEM 11) <b>03-Jul-2002</b>	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE          RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN          REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment 0005 to solicitation number DACA51-02-R-0017 is change the specifications under Section 00110, Submission Requirements and Instructions: Paragraph 3.7.2. Schedule, as per attached, provide answers to potential offerors' questions as attached, to establish a cutoff for solicitation questions at 10 a.m. on 27 August 2002, and to clarify the pricing schedule, as per attached.  NOTE: Offerors must acknowledge receipt of this amendment by the date specified in the solicitation (or as amended) by one of the following methods: In the space provided on the SF 1442, by separate letter, or by telegram, or by signing block 15 below. <b>FAILURE TO ACKNOWLEDGE AMENDMENTS BY THE DATE AND TIME SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER IN ACCORDANCE WITH THE LATE OFFER, LATE MODIFICATIONS OF OFFERS, OR LATE WITHDRAWAL OF OFFERS (FAR 14.304).</b>  The pricing proposal due date remains unchanged at 29 August 2002, 1400 hours local time (2:00 P. M.).  Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  <b>23-Aug-2002</b>	

EXCEPTION TO SF 30  
APPROVED BY OIRM 11-84

30-105-04

STANDARD FORM 30 (Rev. 10-83)  
Prescribed by GSA  
FAR (48 CFR) 53.243

## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

Section 00010 - Solicitation Contract Form

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0001	BASE OFFER All work for the C-17 Maintenance Hangar and Aircraft Maintenance Shops as described in the plans and specifications, including all plant and labor, complete and excluding items below.	1	Lump Sum		

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0002	Site work-BASE OFR. all work outside the five-foot line of the building perimeter.	1	Lump Sum		

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0003	BASE OFFER All design services excluding design services for optional bid items.	1	Lump Sum		

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0004	Pre-Price Line Item All work for the Final Record Drawing Submission (See paragraph 10 of Section 0800). BASE OFFER	1	Lump Sum		\$25,000.00

TOTAL BASE OFFER (ITEMS 0001-0004): \$\_\_\_\_\_

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0005	OPTIONAL BID ITEM NO. 1	1	Lump Sum		
OPTION	Additional work for the inclusion of the Canopy on the west side of the Hangar.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0006	OPTIONAL BID ITEM NO. 2	1	Lump Sum		
OPTION	Additional work for the inclusion of the POV Parking Lot and associated access road, sidewalk, and area lighting .				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0007	OPTIONAL BID ITEM NO. 3	1	Lump Sum		
OPTION	Additional work for the inclusion of the Landscaping and associated irrigation.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0008	OPTIONAL BID ITEM NO. 4	1	Lump Sum		
OPTION	Additional work for the inclusion of the Lockers.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0009	OPTIONAL BID ITEM NO. 5	1	Lump Sum		
OPTION	Additional work for the inclusion of the Light Reflective Dry Shake Quartz Floor Hardener in Hangar Bay 114, Wheel and Tire Shop 135, Repair and Reclamation Shop 139, Pneudraulics Shop 141, Sheet Metal shop 156, Corrosion Control/composite Shop 159, and Machine Shop 168.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0010	OPTIONAL OFFER ITEM No. 6	1	Lump Sum		
OPTION	Additional work for the inclusion of the Insulated Translucent Fiberglass Sandwich Panels on the North Face of the High Bay exterior walls.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0011	OPTIONAL BID ITEM NO. 7	1	Lump Sum		
OPTION	Additional work for the inclusion of the Insulated Translucent Fiberglass Sandwich Panels on the East and West Faces of the High Bay exterior walls.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0012	OPTIONAL BID ITEM NO. 8	1	Lump Sum		
OPTION	Additional work for the inclusion of the Standby Power Generator.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0013	OPTIONAL BID ITEM NO. 9	1	Lump Sum		
OPTION	FFP Additional work for the inclusion of the Bridge Cranes.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0014	OPTIONAL BID ITEM NO. 10	1	Lump Sum		
OPTION	Additional work for the addition of a wood shadow-box type construction fence in lieu of a chain-link construction fence, and to paint the dumpsters, trash containers and temporary sanitation facilities, and contractor trailers, offices and storage buildings, the standard Base colors.				

ITEM NO	SUPPLIES/SERVICES	QUANTITY	UNIT	UNIT PRICE	AMOUNT
0015	OPTIONAL BID ITEM NO. 11	1	Lump Sum		
OPTION	Deduct price for designing and building the project in English inch-pound (I-P) units in lieu of International System of Units (SI) as shown on the Contract Documents.				

**TOTAL OPTION OFFER ITEMS (0005-0015):** \$ \_\_\_\_\_

**TOTAL BASE OFFER WITH OPTIONAL ITEMS (0001-0015):** \$ \_\_\_\_\_

## SECTION 00800 - SPECIAL CONTRACT REQUIREMENTS

The following have been added by full text:

### A0005 CHANGES

## **AMENDMENT 0005 TO DRAWINGS AND SPECIFICATIONS FOR FY 02 C17 MAINTENANCE HANGAR AND AIRCRAFT MAINTENANCE SHOPS, McGUIRE AFB, NEW JERSEY – DACA51-02-R-0017**

### **TO OFFERORS**

The following changes shall be made to the drawings and specifications.

### **SPECIFICATIONS**

1.) The following SPECIFICATIONS have been **REVISED** as indicated below.

### **Section 00110, Submission Requirements and Instructions**

Paragraph 3.7.2. Schedule **Change** “This schedule shall clearly show how it compares to the number of calendar days and the sequence of construction as stated in section 00800 of the RFP.” Change to ” Submit a detailed revised schedule based on a 730 calendar day duration no later than 29 August 2002. This schedule shall clearly show the sequence of construction as stated in section 00800 of the RFP.

### **Section 01010, Design Requirements**

**ADD** at end of Paragraph 8.2.6 the following:

“Design and installation of Communications and Information Systems shall conform to the Communications Squadron “base standard” – (ETL)01-17: Communication and Information System Criteria for Air Force Facilities.”

Paragraph 5.9, **REVISE** as follows:

“Reference Sheet IF601 for room finish schedule. Minimum ceiling heights are indicated.”

Paragraph 8.3.12

- a.) **REVISE** General illumination levels defined for Janitors Closets and Storage Rooms from 54 Lux to 107 Lux respectively.

**BIDDER'S QUESTIONS AND GOVERNMENT REPLY**

(Questions that may be of general interest of all bidders/Government and that are not readily answered by the proceeding changes will appear below. These questions may have been paraphrased or altered to represent several questions regarding the same subject and/or clarify and simplify the question(s). Questions and answers are issued to the Offerors/Bidders for information only.)

Question 1: Please provide us with a specification section for the Light Reflective Dry Shake Quartz Floor Hardener, additional work of which is required in the optional bid Item No. 5.

**Refer to Specification Section 03300, Paragraph 3.12.7.**

Questions 2: There are two draft curtains shown on the SF102 drawing, but there is no specification for them. Also, there is no indication what material the curtains are made of, what manufacturer, what size, etc. Please provide us with information on the draft curtains (specification section, manufacturer name, etc.)

**Draft curtains shall be constructed of non-combustible materials suitable for the intended purpose and in accordance with Engineering Technical letter (ETL) 01-2: Fire Protection Engineering Criteria – New Aircraft Facilities, Paragraph A1.1.1.5 and additional provisions of the RFP.**

(End of Summary of Changes)